

California Environmental Protection Agency



Vapor Recovery Test Procedure

PROPOSED TP - 201.5

DETERMINATION (BY VOLUME METER) OF
AIR TO LIQUID VOLUME RATIO OF
VAPOR RECOVERY SYSTEMS OF
DISPENSING FACILITIES

Adopted: April 12, 1996
Amended: _____

**California Environmental Protection Agency
Air Resources Board**

Vapor Recovery Test Procedure

TP-201.5

**Determination (by Volume Meter) of
Air to Liquid Volume Ratio of
Vapor Recovery Systems of
Dispensing Facilities**

1 APPLICABILITY

- 1.1 This test procedure is used to quantify the Air to Liquid (A/L) Volumetric Ratio of Phase II vapor recovery systems installed at gasoline dispensing facilities (GDF), provided the nozzles use a coaxial spout design, or equivalent. This procedure provides a method to determine compliance with the A/L requirements specified in the applicable California Air Resources Board (CARB) Executive Order (EO) for the specified Phase II vapor recovery system.

2 PRINCIPLE

- 2.1 A tight fitting adaptor is placed on the spout of a dispensing nozzle. The adaptor, which isolates air flow to the nozzle vapor collection ports, is connected to a rotary gas meter, or equivalent. Gasoline is dispensed through the nozzle and the volume of air and vapors drawn through the vapor collection ports by the Phase II system vacuum pump is measured. The volume of the air mixture is recorded and compared with the volume of gasoline dispensed to determine the A/L Volumetric Ratio.

3 RANGE AND SENSITIVITY

- 3.1 The maximum rated capacity of the rotary gas meter shall be at least 800 CFH and not greater than 3,000 CFH.
- 3.2 The minimum readability of the rotary gas meter shall be 0.01 cubic feet.

4 INTERFERENCES

- 4.1 Nozzle spouts which are damaged such that the A/L adaptor cannot fit over the nozzle spout preclude the use of this test.


- 4.2 Dispensing rates below the minimum rates specified in the applicable CARB EO preclude the use of this test.
- 4.3 Location or configuration of the vapor collection ports on the nozzle spout which are not compatible with the A/L adaptor specified in this procedure preclude the use of this test.
- 4.4 Bagging, or otherwise sealing any nozzle associated with the vacuum pump serving the nozzle being tested, may bias the test results towards compliance. **The A/L test to verify compliance shall be conducted without “bagging” any of the nozzles served by a common vacuum device.**
- 4.5 If the nozzle being tested introduces liquid into the test equipment, the A/L of that nozzle shall be deemed a failure.

5 APPARATUS

- 5.1 Air to Liquid Adaptor. Use an Air to Liquid (A/L) adaptor compatible with the nozzle(s) employed at the GDF. The adaptor shall be capable of isolating the vapor holes in the nozzle and be connected to the rotary gas meter with flexible tubing. The nominal inside diameter of the flexible tubing shall be between 0.75 and 1.00 inches, and the maximum length of the tubing shall be 8 feet. Figure 1 illustrates an A/L adaptor assembled on a nozzle. If certain adaptors are referenced in the applicable CARB EO, only those adaptors shall be used.

Figure -1

Rotary Gas Meter and Air To Liquid Adaptor



- 5.2 Rotary Gas Meter. Use a Dresser Measurement Roots Meter, or equivalent, to measure the volumetric flowrate through the A/L adaptor. The meter shall be equipped as shown in Figure 1 and the maximum allowable pressure drop(s) across the meter shall be as follows:

For a meter with a maximum rated capacity of 1000 CFH through 3,000 CFH:

1.10 inches H₂O at a flowrate of 3,000 CFH
0.05 inches H₂O at a flowrate of 30 SCFH.


For a meter with a maximum rated capacity of 800 to 1,000 CFH:

0.70 inches H₂O at a flowrate of 800 CFH
0.04 inches H₂O at a flowrate of 16 CFH

- 5.3 Liquid Volume Meter. Use the totalizer on the gasoline dispenser to measure the volume of gasoline dispensed during the test.

Figure 2

Portable Tank Assembly



- 5.4 Portable Gasoline Tank Assembly. A portable tank, acceptable for use with gasoline, shall be used to receive the gasoline dispensed during this test. The tank shall have sufficient

volume so that at least 4.5 gallons may be dispensed prior to activating the primary shutoff mechanism of the dispensing nozzle. Tank material, likely to provide contact with the nozzle spout during the entire dispensing event, shall be constructed of aluminum or brass or other materials approved by the local fire codes for such application. The tank and recommended plumbing configuration is shown in Figures 39-2 and Figure 39-3. This configuration permits a portion of the vapors displaced during testing to be returned to the gasoline storage tank. The minimum and maximum dimensions shown in Figure 2 and Figure 3 shall be adhered to in all cases.


5.5 Stopwatch. Use a stopwatch accurate to within 0.2 seconds.

6 PRE-TEST PROCEDURES

- 6.1 Assemble the portable tank assembly and rotary gas meter as shown in Figure 3. The minimum and maximum dimensions shown in Figure 3 shall be adhered to in all cases. **Ensure that the ground strap is properly connected to an acceptable ground.** The tank shall only be used when it is on the ground, not in the back of a pickup or trailer, unless the pick-up is safely grounded.
- 6.2 If more than one nozzle shares vacuum plumbing with the test nozzle, one troubleshooting method for a low A/L ratio is to seal all nozzles other than the nozzle being tested, e.g., plastic bags and tape or rubber bands. If leaks in the nozzles/check valves served by common vacuum pump cause the bags to deflate, the low A/L ratio may have been caused by a leak through an idle nozzle during the test. **The A/L test to verify compliance, however, shall be conducted without “bagging” any of the nozzles.**

Figure 3


Assembled Air To Liquid Volume Ratio Test Equipment



- 6.3 The rotary gas meter shall be calibrated at flowrates of 30, 60, and 90 CFH at intervals not to exceed one year per EPA Method 2A, Measurement of Gas Volume Through Pipes and Small Ducts. A copy of the most current calibration shall be kept with the meter.
- 6.4 A one-time test to verify proper design of the tee connection at the rotary gas meter shall be conducted. Disconnect the A/L adaptor from the nozzle and dispense four and one half (4.5 ± 0.3) gallons into the portable test can, insuring a tight fit at the nozzle spout/portable tank fill pipe. The design is acceptable if the displacement on the rotary gas meter is less than 0.01 cubic feet.
- 6.5 Verify that the O-rings in the A/L adaptor, if applicable, are present and in good condition. O-rings with nicks, tears, or other deformations shall be replaced prior to the test. The O-rings shall be properly greased to ensure a vapor tight connection.

Figure 4

Air To Liquid Adapter Leak Test Assembly



- 6.6 Conduct a pre-test leak check of the A/L adaptor by connecting the A/L adaptor to a surrogate spout as shown in Figure 4. Raise the test pressure to five inches H_2O , gauge (5.00"WCg). Squirt liquid leak detector solution on interfaces and other potential leak sources while watching for the formation of bubbles. There shall be no formation of bubbles, or a drop in pressure below 4.95 "WCg for three minutes from the start of the test. Any A/L adaptor which fails this pre-test leak check shall not be used to conduct A/L testing for the purpose of determining compliance.

- 6.7 This test procedure shall be conducted with the storage tank pressure/vacuum (P/V) valve(s) installed and the Phase I poppetted vapor coupler(s) in the closed position, unless otherwise specified in the applicable CARB EO.

7 TESTING

- 7.1 Carefully connect the A/L adaptor to the nozzle spout as shown in Figure 1, isolating the vapor ports of the nozzle and insuring a tight connection.
- 7.2 Record the initial reading from the index of the rotary gas meter on the A/L Field Data Summary, as shown in Form 1. This initial reading shall be taken before each test. Do not use the final reading from the preceding test as the initial reading for the current test, unless it has been verified. This is necessary since the meter index may have moved due to the low pressure drop through the meter.
- 7.3 Reset the stopwatch and, if appropriate, reset the totalizer on the dispenser.
- 7.4 Fully engage the nozzle trigger and begin dispensing into the portable gasoline tank. **Ensure that the nozzle spout is in contact with the grounded tank assembly during dispensing.** Start the stopwatch when the totalizer indicates dispensing has started.
- 7.5 Dispense between four and one-half (4.5) and five (5.0) gallons of gasoline. If the applicable CARB Executive Order specifies an amount different than this range, the CARB required quantity shall be used.
- If the nozzle being tested introduces liquid into the test equipment, the A/L of that nozzle shall be deemed a failure.
- 7.6 Simultaneously stop both the stopwatch and gasoline dispensing.
- 7.7 The following data for each test shall be recorded on the A/L Field Data Summary as shown in Form 39-1:
- 7.7.1 Dispenser (pump) number
 - 7.7.2 Gas grade
 - 7.7.3 Nozzle model and serial number
 - 7.7.4 Initial rotary gas meter reading, in cubic feet
 - 7.7.5 Initial totalizer reading from the dispenser, in gallons

- 7.7.6 Final rotary gas meter reading, in cubic feet
- 7.7.7 Final totalizer reading from the dispenser, in gallons
- 7.7.8 Elapsed time during dispensing, in seconds

NOTE: Units other than cubic feet, gallons, and seconds may be used, provided that Equation 9-1 is appropriately modified.

- 7.8 If the A/L Volumetric Ratio, as determined by Equation 9-1 is within the limits specified in the applicable CARB EO, the refueling point complies with the specifications of the applicable EO.
- 7.9 If the difference between the **minimum or maximum allowable** A/L Volumetric Ratio specified in the CARB EO and the A/L Volumetric Ratio, as determined by Equation 9-1, is **greater than 0.10**, the refueling point does not comply with the specifications of the applicable CARB EO.

If the difference between the minimum or maximum allowable A/L Volumetric Ratio specified in the CARB EO and the A/L Volumetric Ratio, as determined by Equation 9-1, is less than or equal to 0.10, conduct the test two additional times. Calculate the numerical average of the three test runs. If the average A/L value of these three test runs is within the allowable limits, compliance has been verified. If the resulting average is outside of the specified limits, the refueling point does not comply with the specifications of the applicable CARB EO.

- 7.10 If more than one nozzle share vacuum plumbing with the test nozzle, one troubleshooting method for a low A/L ratio is to seal all nozzles other than the nozzle being tested, e.g., plastic bags and tape or rubber bands. If leaks in the nozzles/check valves served by common vacuum pump cause the bags to deflate, the low A/L ratio may have been caused by a leak through an idle nozzle during the test. **The A/L test to verify compliance, however, shall be conducted without “bagging” any of the nozzles.**
- 7.11 Conduct the A/L Volumetric Ratio test on each nozzle at the facility, unless otherwise specified in the applicable CARB Executive Order.
- 7.12 Periodically, or as necessary to avoid a build-up of gasoline, drain any condensed gasoline from the hoses between:
 - (a) the rotary gas meter and portable tank assembly, and
 - (b) the A/L adaptor and rotary gas meter.

8 POST-TEST PROCEDURES

- 8.1 Remove the A/L adaptor from the nozzle.

- 8.2 Drain the dispensed product into the appropriate gasoline storage tank at the facility. Do not mix product grades in the portable tank assembly and use caution to drain the portable tank into the correct facility storage tank. If blending valves are utilized to produce product grades which do not have an underground tank, product from the blended grade shall be returned to the lower octane tank.
- 8.3 At the conclusion of testing at the facility, conduct a post-test leak check of the A/L adaptor by connecting the A/L adaptor to a surrogate spout as shown in Figure 39-4. Raise the test pressure to five inches H₂O, gauge (5.00"WCg). Squirt liquid leak detector solution on interfaces and other potential leak sources while watching for the formation of bubbles. There shall be no formation of bubbles, or a drop in pressure below 4.95 "WCg for three minutes from the start of the test. The data collected during the A/L testing is invalid if the A/L adaptor fails this post-test leak check.
- 8.4 Prior to transportation, the inlet and outlet of the rotary gas meter shall be carefully sealed to prevent foreign matter from entering the meter.
- 8.5 At the conclusion of testing, the portable tank shall be transported in accordance with all applicable safety requirements.

9 CALCULATION

- 9.1 The A/L Volumetric Ratio shall be calculated as shown in Equation 9-1.

$$A / L = \left[\frac{V_f - V_i}{G_f - G_i} \right] \times 7.481 \quad [\text{Equation 9-1}]$$

where:

A/L = Air to Liquid Volumetric Ratio, dimensionless
 V_i = Initial rotary gas meter reading, cubic feet
 V_f = Final rotary gas meter reading, cubic feet
 G_i = Initial totalizer reading from the dispenser, gallons
 G_f = Final totalizer reading from the dispenser, gallons
 7.481 = Conversion factor from gallons to cubic feet, gallons per cubic foot

- 9.2 The gasoline dispensing rate during the A/L test shall be calculated as shown in Equation 9-2.

$$Q_g = \left[\frac{G_f - G_i}{t} \right] \times 60 \quad [\text{Equation 9-2}]$$

where:

| | | |
|-------|---|---|
| Q_g | = | Gasoline dispensing rate, gallons per minute |
| G_i | = | Initial totalizer reading from the dispenser, gallons |
| G_f | = | Final totalizer reading from the dispenser, gallons |
| t | = | Elapsed time during dispensing event, seconds |
| 60 | = | Conversion factor, seconds per minute |

10 REPORTING

- 10.1 The results of the A/L Volumetric Ratio test shall be reported as shown in Form 2. Results submitted for District approval shall also include the A/L Field Data Summary as shown in Form 1.

11 ALTERNATIVE TEST PROCEDURES

Test procedures, other than specified above, shall only be used if prior written approval is obtained from the ARB Executive Officer. In order to secure the ARB Executive Officer's approval of an alternative test procedure, the applicant is responsible for demonstrating to the ARB Executive Officer's satisfaction that the alternative test procedure is equivalent to this test procedure.

- (1) Such approval shall be granted on a case-by-case basis only. Because of the evolving nature of technology and procedures for vapor recovery systems, such approval shall not be granted in subsequent cases without a new request for approval and a new demonstration of equivalency.
- (2) Documentation of any such approvals, demonstrations, and approvals shall be maintained in the ARB Executive Officer's files and shall be made available upon request.

12 ACKNOWLEDGMENTS

This procedure was patterned after a test procedure developed by the Bay Area Air Quality Management District.

Form 39-1

| | | |
|---|--|--------------------------------|
| GDF Name and Address | A/L Field Data Sheet | Testing Firm Name and Address: |
| | | Phone No. () |
| Test Date/Time: | | Test Performed by: |
| Pre-Test Leak Check: Initial/Final Pressures, in. H ₂ O / | Source: GDF Phase II Vapor Recovery | VN Recommendation: |
| Post-Test Leak Check: Initial/Final Pressures, in. H ₂ O / | GDF # A/C # | |

[illegible]

Form 39-2

| | | | |
|---|---|---|---|
| Distribution: Firm Permit Services Enforcement Services Technical Services Planning Requester DAPCO | <h2 style="text-align: center;">Summary of Source Test Results</h2> | | Report No.: _____ |
| | | | Test Date: _____ |
| | | | Test Times: |
| | | | Run A: _____ Run B: _____ Run C: _____ |
| <div style="display: flex; justify-content: space-between;"> Source Information BAAQMD Representatives </div> | | | |
| Firm Name and Address | Firm Representative and Title Phone No. () | Source Test Engineers | |
| Permit Conditions: | Source: Plant No. Permit No. Operates | Permit Services Division/Enforcement Division | |
| | | Test Requested By: | |
| Operating Parameters: | | | |
| Applicable Regulations: | | VN Recommended: | |

Source Test Procedure ST-39, Air to Liquid Volumetric Ratio, Test Results and Comments:

| <u>Nozzle #</u> | <u>Gas</u> | <u>Nozzle</u> | <u>Gallons</u> | <u>Dispensing</u> | <u>Metered</u> | <u>A/L</u> | <u>Pass/</u> |
|-----------------|------------|---------------|----------------|-------------------|----------------|------------|--------------|
| 1 | | | | | | | |
| 2 | | | | | | | |
| 3 | | | | | | | |
| 4 | | | | | | | |
| 5 | | | | | | | |
| 6 | | | | | | | |
| 7 | | | | | | | |
| 8 | | | | | | | |
| 9 | | | | | | | |
| 10 | | | | | | | |
| 11 | | | | | | | |
| 12 | | | | | | | |

Comments:

| | | | | |
|-------------------------|------|----------------------------------|------|---|
| Air Quality Engineer II | Date | Supervising Air Quality Engineer | Date | Approved by Air Quality Engineering Manager |
|-------------------------|------|----------------------------------|------|---|